



LARGE ROUND PLASTIC JUNCTION BOX

NOTES

1. REFER TO CONTRACT DRAWINGS AND SECTION 34 41 13 FOR DETAILED SPECIFICATION
2. ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE NOTED
3. INSTALL LID ON PLASTIC JUNCTION BOX BEFORE BACKFILLIE, TAMPING & PAVING OPERATIONS
4. INSTALL TOP OF PLASTIC JUNCTION BOX FLUSH WITH FINISH GRADE
5. INSTAL ELECTRODE PLATE ON UNDISTURBED GROUND

NUMBER OF CONDUITS ENTERING JUNCTION BOX NOT TO EXCEED 10 (UNLESS OTHERWISE NOTED)

STANDARD DETAIL DRAWING	DATE: 07/20/20	LARGE ROUND PLASTIC JUNCTION BOX DETAILS	DWG. NO.	City of Kelowna
	SCALE: NTS		SS-E2.1	