



**NOTES:**

- 1.) THE SITE LAYOUT IS INTENDED TO PROVIDE GENERAL GUIDANCE FOR PLACEMENT OF EQUIPMENT, SETBACKS, AND ACCESS. EVERY SITE WILL HAVE UNIQUE SITE SPECIFIC CHALLENGES THAT MAY AFFECT THE OVERALL LAYOUT. THESE ISSUES ARE TO BE DEALT WITH DURING PLANNING AND DESIGN PHASES.
- 2.) IF PERMANENT GENSET IS NOT REQUIRED, PROVIDE A LOCATION FOR A PORTABLE GENSET.
- 3.) CONDUIT FROM KIOSK TO PROPERTY LINE REQUIRED FOR FUTURE FIBRE CONNECTION. TERMINATE IN JUNCTION BOX.
- 4.) CHEMICAL FEED CONDUIT TO BE STUBBED FOR FUTURE ODOUR CONTROL BUILDING.
- 5.) OFF STREET PARKING TO ACCOMMODATE A VACUUM TRUCK (HSU) AND FULL SIZE PICKUP TRUCK SIMULTANEOUSLY.
- 6.) ANTENNA MAST LOCATION TO BE DETERMINED BASED ON SITE CONDITIONS.
- 7.) ENTIRE SITE TO BE PAVED AND FENCED C/W VEHICLE ACCESS GATES AND MAN GATE.
- 8.) IF ODOUR CONTROL BUILDING IS REQUIRED, AN ADDITIONAL 13MX13M AREA MAY BE REQUIRED.
- 9.) CONCRETE BASES FOR TRANSFORMER, ELECTRICAL KIOSK AND GENSET TO BE 200MM ABOVE GRADE.

**LEGEND**

- ① TRANSFORMER
- ② ELECTRICAL KIOSK
- ③ GENSET
- ④ PIGGING PORT PER DRAWING SS-S62

**STANDARD  
DETAIL  
DRAWING**

DATE:  
06/22/20  
SCALE:  
NTS

**TYPICAL LIFT STATION  
SITE LAYOUT**

DWG. NO.  
**SS-S59**

