



- NOTE:**
1. CONNECTIONS TO BE 100mm DIAMETER FOR SANITARY AND 150mm FOR STORM.
 2. RISER TYPE SERVICE (FROM MAIN) TO BE USED ONLY WHEN SERVICE IS MORE THAN 2.4m ABOVE WYE INVERT.
 3. LOCATION OF SERVICE AND MARKER AS SHOWN ON CONTRACT DRAWINGS.
 4. SEE DRAWING SS-S9 FOR DETAILS OF INSPECTION CHAMBER, BROOKS BOX AND INSTALLATION REQUIREMENTS.
 5. 2.0m TYPICAL. WHEN ON LOW SIDE OF ROAD AND PIPE DEPTHS > 2.0m, USE 4.0m
 6. HORIZONTAL SEPARATION BETWEEN SANITARY SEWER SERVICE AND ADJUST WATER AND STORM SERVICES TO BE MINIMUM OF 0.5m

SANITARY AND STORM SEWER SERVICE CONNECTION

DRAWING NUMBER
SS-S7