



**NOTES:**

1. ALL PIPE & FITTINGS TO BE PER APPROVED PRODUCTS LIST.
2. THIS ASSEMBLY TO BE USED IN STATUTORY RIGHT OF WAYS WHERE POWER IS NOT READILY AVAILABLE.
3. CONTRACTOR TO ENSURE ALL PIPING FROM CORP. STOP TO AIR VALVE IS INSTALLED WITH POSITIVE GRADE, INCLUDING COIL TUBING INSIDE AIR RELEASE VAULT.
4. CONTRACTOR TO ENSURE STEEL PLATFORM FOR AIR VALVE CAN BE PULLED UP & OUT OF AIR RELEASE VAULT.

**STANDARD  
DETAIL  
DRAWING**

DATE:  
JUN 28/24  
SCALE:  
NTS

**25mm UNDERGROUND  
AIR VALVE**

DWG. NO.

**SS-W6a**

